



**ADDENDUM NO. 1**

**CITY OF CORNING  
CONTRACT DOCUMENTS FOR:  
2019 STREET IMPROVEMENT PROJECT  
ELIZABETH AVE. & FAIRVIEW AVE.  
Project No. 2018-18  
Dated: April 19, 2019**

The purpose of this Addendum No. 1 is to modify the Contract Documents for the above project. This Addendum shall be attached to and become a part of said Contract Documents. **THIS ADDENDUM SHALL BE SIGNED BY THE BIDDER, DATED, AND SUBMITTED WITH THE BID PROPOSAL FOR THE PROJECT.**

**Addendum No. 1; Item No. 1:**

1. **CLARIFICATION/PLAN UPDATE:** The City of Corning staff will remove all trees on Elizabeth Ave. and Fairview Ave. prior to the start of construction. Please delete tree removal from the proposed bids.

**Addendum No. 1; Item No. 2:**

1. **CLARIFICATION:** Construction of the proposed project needs to be completed no later than **June 30, 2019** due to funding restrictions.

**Addendum No. 1; Item No. 3:**

1. **QUESTION:** Will the Contractor be responsible for compaction testing and asphalt material and placement testing?

**ANSWER:** The City of Corning will hire an independent firm to complete the compaction testing and to perform all asphalt testing. The Contractor shall coordinate through the City for inspections and scheduling of required tests.

**Addendum No. 1; Item No. 4:**

1. **QUESTION:** It does not appear that there is an asphalt mix design in the specifications.

**ANSWER:** The plans specify Type A asphalt per Caltrans Standard Specification 2015 Section 39, "Asphalt Concrete."

This Addendum consists of a total of 1-page.

Prepared by:

Name: \_\_\_\_\_

***Robin Kampmann***

Robin Kampmann, PE  
Public Works Consultant/City Engineer Consultant

Address: \_\_\_\_\_

\_\_\_\_\_

Signature: \_\_\_\_\_

Bidder

Phone: \_\_\_\_\_

E-Mail: \_\_\_\_\_

Date: \_\_\_\_\_