

ADDENDUM NO. 1

**CITY OF CORNING
CONTRACT DOCUMENTS FOR:
HELISIEVE HLS400 REPAIR
WASTE WATER TREATMENT PLANT
Project No. 2018-17
Dated: October 24, 2018**

The purpose of this Addendum No. 1 is to modify the Contract Documents for the above project. This Addendum shall be attached to and become a part of said Contract Documents. **THIS ADDENDUM SHALL BE SIGNED BY THE BIDDER, DATED, AND SUBMITTED WITH THE BID PROPOSAL FOR THE PROJECT.**

Addendum No. 1; Item No. 1:

1. **CLARIFICATION:** The Helisieve HLS400 Serial Number is 23054302.

Addendum No. 1; Item No. 2:

1. **QUESTION:** Can the Helisieve be taken offline, removed from the site and reconstructed remotely?

ANSWER: The Helisieve can be taken offline and the flow bypassed through an existing bar screen for a time not to exceed 1 week. Therefore all repair work to the Helisieve must be performed onsite to reduce the amount of time the Helisieve is offline.

Addendum No. 1; Item No. 3:

1. **ADD TO** Technical Specifications Part 1 – General, 1.1 Summary

Repair work includes the replacement of the existing spiral assembly, including the brush and shoes and the ¼" screen basket. *Once the spiral assembly is removed from the gear box the contractor shall also replace the two (2) oil seals that are located within the gearbox prior to the reassembly of the helisieve.*

Addendum No. 1; Item No. 4:

1. **ADD TO** Technical Specifications Part 3 – Execution

The existing spiral assembly and screen basket shall remain the property of the City of Corning and remain onsite at the Waste Water Treatment Plant.

This Addendum consists of a total of 1-page.

Dated: October 24, 2018

Prepared by:

Name: _____

Robin Kampmann,
Director of Public Works

Address: _____

Signature: _____
Bidder

Phone: _____

Fax: _____

Date: _____

E-Mail: _____